



Emergency Scene Illumination

NFPA 1001 [2013] - 5.3.17

REQUIRES HOME DEPARTMENT

NYS DIVISION OF HOMELAND SECURITY & EMERGENCY SERVICES

NYS Skill Sheet 10-I-1

_____ Candidate's Name	_____ Date
_____ Evaluator's Name	_____ Evaluator's Signature

The candidate, given a complete set of PPE and a portable electric generator, electric extension cords, and portable lighting equipment, employing all safety precautions and operating individually, shall illuminate an area(s) as directed by the evaluator in accordance with IFSTA Essentials of Fire Fighting and Fire Department Operations, 6th ed.

Criteria:	DEPT	INSTR
Considers grounding of generator [may be verbalized]		
Assures generator readiness and performance [checks fuel/oil]		
Identifies limitations of power supply equipment [load cannot exceed amperage of circuit breaker, total load cannot exceed output of generator, and fuel dependent]		
Identifies hazards associated with electric generating equipment [wet environment, tight connections, and ventilation of exhaust]		
Operates equipment within manufacturer's guidelines		
Illuminates area(s) as directed		
Clean equipment as needed and remove damaged equipment from service and report to company officer.		
Refuel powered equipment as needed and return to service.		
	INITIAL	INITIAL

Evaluator Notes: