



Rolling Hose

NFPA 1001 [2013] - 5.5.2

REQUIRES HOME DEPARTMENT SIGN OFF

NYS DIVISION OF HOMELAND SECURITY & EMERGENCY SERVICES

NYS Skill Sheet 15-I-3, 15-I-4

Candidate's Name _____	Date _____
Evaluator's Name _____	Evaluator's Signature _____

The candidate, given appropriate PPE, will demonstrate a straight roll and a donut roll in accordance with IFSTA Essentials of Fire Fighting and Fire Department Operations, 6TH ed. JPR 5.5.2

Criteria:	DEPT	INSTR
STRAIGHT HOSE ROLL		
Lays hose out straight and flat		
Rolls male coupling onto hose, starting the roll, leaving an opening large enough to insert fingers		
Continues rolling, forming an even roll		
As hose roll increases in size, edges are kept aligned		
Checks for uniformity, and any protruding coils are gently tamped into coil		
Finished hose roll is neat and tight, and stays together when lifted		
DONUT HOSE ROLL		
Lays hose out flat and straight, or doubles the hose with couplings even, and hose flat and parallel		
There are no twists in the hose		
Starts roll at a point off-center of hose, toward the male coupling		
Rolls hose toward female coupling [straight method], or toward male coupling [parallel method]		
Leaves sufficient space to insert fingers in roll		
When complete, male coupling is enclosed within roll by one layer of hose only and is behind the female coupling by a minimum of 12"		
Finished hose roll is neat and tight, and stays together when lifted		
	INITIAL	INITIAL

Evaluator Notes on back: