

2018 Combined Sewer Overflow Annual Report

Village of Oak Harbor

							Fire Station 2PB00032003		Locust Street 2PB00032005		Church Street 2PB00032006		Portage Street 2PB00032008		Mylander 2PB00032009		Marathon 2PB00032010		2PB00032300		
Operator	Date	Daily Rain Amt.	Rain Totals per event	Daily MGD effluent	Total MGD @Plant per event	Treatment	Estimated Amount MGD	Estimated Overflow Total R.E.	Estimated Amount MGD	Estimated Overflow Total R.E.	Estimated Amount MGD	Estimated Overflow Total R.E.	Estimated Amount MGD	Estimated Overflow Total R.E.	Estimated Amount MGD	Estimated Overflow Total R.E.	Estimated Amount MGD	Estimated Overflow Total R.E.	Estimated Amount MGD	Estimated Overflow Total R.E.	Reason for overflow
MA	2/17/2018	0.52		2.465							0.25										Rain
MA	2/18/2018	0.56		2.190							0.10										Rain
MA	2/19/2018	0.67		2.179							0.10										Rain
MA	2/20/2018	0.23		2.825							0.25										Rain
MA	02/21/18	0.09		2.985							0.50										Rain
MA	02/22/18	0.00		2.852							0.35										Rain
MA	02/23/18	0.00	2.07	3.172	18.67	None					0.75	2.3									Rain
MA	04/15/18	2.26		2.379							0.20										Rain
MA	04/16/18	0.04		2.946							0.20										Rain
MA	04/17/18	0.01	2.31	2.840	8.17	None					0.10	0.5									Rain
MA	05/03/18	1.41	1.41	2.708	2.71						0.02	0.02									Rain
MA	06/12/18	4.75		3.122			1.10		0.70		1.00		0.50		0.75						Rain
MA	06/13/18	0.00		2.925			0.20	1.30	0.05	0.75	0.50	1.50	0.25	0.75	0.25	1.00			0.35		Rain
MA	06/14/18	0.00		2.620															0.50		Rain
MA	06/15/18	0.00	4.75	2.076	10.74	None													0.25		Rain
MA	06/27/18	0.38		2.841							0.25										Rain
MA	06/28/18	2.12	2.5	2.645	5.49	None					0.25	0.5									Rain

* All overflows were released into the Portage River

2018 Annual Report was based on data provided by the Oak Harbor Wastewater Plant

Person responsible for maintaining the Municipal Website: Village Administrator Randall Genzman Contact No. (419) 898-5561 or randyg@oakharbor.oh.us