

TOWNSHIP OF DENVILLE
1 ST. MARY'S PLACE
MORRIS COUNTY, NEW JERSEY
Department of Public Works Purchase of
Water Fittings and Valves
Municipal Bid #1-2020

ADDENDUM NO. 3

June 17, 2020

TO ALL CONCERNED:

The original Contract Documents dated June 3, 2020, for the above-referenced Contract are amended as noted in this Addendum. This Addendum shall become a part of the Contract Documents and is to be attached thereto.

Bidders are reminded that they **must** acknowledge receipt of all addenda on the designated page entitled "Acknowledgement of Receipt of Bid Changes Form"

RE: Correction to multiple items and change in bid date

Delete: Bid opening date of June 23, 2020 at 11am and June 25, 2020

Add: Bid opening date of July 30 at 11am

Clarification of items:

Vendor questions referenced exactly how they were received and the Township clarification is written below in all caps.

Line Item 1-6 You are asking to include retainers are you looking for a mega-lug as the retainer or a gland pack also would like to know if this is open left or open right

- MEGA LUG RETAINERS. OPEN LEFT VALVES.

Line Item 7 I need to know if you are looking for a specific vendor like Bingham & Taylor or Tyler union does this include a #6 base and is this slip type or screw

- SLIP TYPE. TYPE OR EQUIVALENT

Line Item Line item 9-11 Slip Type or screw on the valve box and should I assume 4-5 trench

- SLIP TYPE. 4-5 TRENCH

Line item 26 through 30 need OD of the pipe or at least type of pipe so I know what range I am trying to cover

- NOT PUTTING SEPARATE LINES FOR EVERY POSSIBLE O.D./PIPE TYPE/CLAMP LENGTH CONFIGURATION. PRICE SHOULD COVER CLAMPS FOR CAST IRON, A/C, DUCTILE PIPE AS SPECIFIED WITHIN THE SIZE.

Line Item 31 through 32 Cast Iron or Stainless rod and the curb box your referencing is Canadian

- STAINLESS ROD. TYPE OR EQUIVALENT

Line Item 33 need OD or type of pipe the 226 will be going on to be sure I am quoting the correct range

- NOT PUTTING SEPARATE LINES FOR EVERY POSSIBLE O.D./PIPE TYPE/CLAMP LENGTH CONFIGURATION. PRICE SHOULD COVER CLAMPS FOR CAST IRON, A/C, DUCTILE PIPE AS SPECIFIED WITHIN THE SIZE.

Line Item 34 through 37 Mueller does not make valve boxes any longer so I am assuming pavement adapters and rite hite adapter please confirm

- TYPE OR EQUIVALENT

Line Item 50 through 55 Need length of clamp as well as O.D.

- NOT PUTTING SEPARATE LINES FOR EVERY POSSIBLE O.D./PIPE TYPE/CLAMP LENGTH CONFIGURATION. PRICE SHOULD COVER CLAMPS FOR CAST IRON, A/C, DUCTILE PIPE AS SPECIFIED WITHIN THE SIZE.

Darlene Price, QPA
Township of Denville