

TOWNSHIP OF DENVILLE
MORRIS COUNTY, NEW JERSEY
1 St. Mary's Place
Denville, NJ 07834

Fire Department Breathing Air System

ADDENDUM NO. 1

Municipal Bid # 9-2018
Issued October 17th, 2018

TO ALL CONCERNED:

The original Contract Documents dated October 17, 2018, for the above-referenced Contract are amended as noted in this Addendum. This Addendum shall become a part of the Contract Documents and is to be attached thereto.

1. In reference to the Bid specifications

Add: Additional 10 pages of information regarding the equipment being specified.

2. **Delete:** Original Bid date: November 8th at 11:30am

Add: Correction to the Notice to Bidders

New Bid Date: November 15th, 2018 at 11am.

Bidders are reminded that they must acknowledge receipt of all addenda on the designed page of the bid documents.

Darlene Price, QPA
Township of Denville

6000 PSI SERVICE

The breathing air station shall be supplied on a steel base frame of welded construction. The frame shall be designed for both the static and dynamic loads of the system and of sufficient size to adequately accommodate all of the station's components. The base frame shall include four brackets to facilitate securing the leveled unit to a concrete floor using expansion anchors. The compressor, purification system, fill station and all tubing shall be incorporated into an appliance-like enclosure complete with sound attenuation. The enclosure panels shall be equipped with a slam-action latches and lift-off hinges making it simple to facilitate inspection and maintenance. The enclosure and base frame shall be finished with a baked on polyester powder coat paint for the ultimate in durability, corrosion resistance, and long life. Space is extremely limited. The unit must be 72" L x 34" W x 70" H.

Yes _____ No _____

The station shall be designed for against-the-wall installation, operation, maintenance and single-point operator control from the front of the station. The design of the station shall permit unrestricted cooling air flow to the compressor and motor when installed against a wall. All system instrumentation, controls and access to the containment fill station shall be located at the front of the station. The compressor package shall fit through a standard 36" doorway. The station shall be designed for continuous duty operation indoors with room temperatures ranging between 40°F and 115°F. Installation shall not require a special foundation; however, it is the responsibility of the purchaser to ensure the installation site has a solid and level foundation that can support the weight of the station, the availability of a qualified source of air for the intake of the compressor and adequate ventilation.

Yes _____ No _____

All piping and tubing shall be properly supported and protected to prevent damage from vibration during shipment, operation, or maintenance. Piping and tubing shall be installed in a neat and orderly arrangement, adapting to the contours of the station. All instrument tubing shall be 300 series stainless steel.

Yes _____ No _____

The station shall be warranted free from defects in material and workmanship for a period of 60 months from date of start-up. The warranty shall not impose limitations on the station's accumulated operating hours during the warranty period.

Yes _____ No _____

Performance Table

| FAD SCFM | Charging Rate SCFM | HP | RPM | Air Processing Capability (cu ft) |
|-------------|--------------------------|----|------|--|
| 10.8 | 13.0 | 10 | 1420 | 67,000 |

Yes _____ No _____

Compressor

The compressor shall be an air-cooled, oil lubricated, four stage, three cylinder, reciprocating compressor. The crankcase shall be cast of a high strength, aluminum alloy. The crankshaft shall be of a single piece forged steel construction, and supported in the crankcase by three long-life roller bearings. The connecting rods shall be of single piece design and constructed of a high strength aluminum alloy. Each connecting rod shall incorporate a roller bearing at the crank end and needle bearing at the pin end. The pistons shall be constructed of an aluminum alloy. Piston rings on the second and third stage are of cast iron; first and fourth stage rings shall be of a high strength polymide. The final stage shall incorporate a ringed, free-floating, aluminum piston, which is driven by a guide piston and the previous stage's discharge pressure. The cylinders shall be of cast iron construction with deep cooling fins on the external surface for optimum heat dissipation. The cylinders shall be arranged in a "W" configuration with the first and second stage sharing one common stepped cylinder. Each cylinder shall be located directly in the cooling fan's blast. The cylinders shall be removable from the crankcase. The compressor's flywheel shall be of cast iron construction. A multi-wing, high velocity cooling fan shall be integral to the flywheel. The Compressor Block must be manufactured by the compressor system OEM. Units that use compressor blocks from 3rd party vendors will not be accepted.

Yes _____ No _____

Inter-stage pressures shall be monitored via locally mounted pressure gauges.

Yes _____ No _____

An intercooler shall be provided after each stage of compression and an aftercooler shall be provided after the final stage of compression. The coolers shall be individually detachable from the compressor, located directly in the cooling fan's blast and made of a stainless steel. The

aftercooler shall be designed to cool the discharge air to within 18°F of ambient temperature. A cool-down cycle shall not be required prior to stopping the compressor.

Yes _____ No _____

A separator shall be supplied after the second and third stages of compression, and a coalescing separator shall be supplied at the discharge of the compressor. An automatic condensate drain (A.C.D.) system shall be supplied for all of the separators. The drain solenoid shall be controlled by the PLC and shall be factory preset to drain the separators approximately every fifteen minutes for approximately six seconds. The A.C.D. system shall unload the compressor on shutdown for unloaded restart. An exhaust muffler and condensate reservoir shall be supplied. The condensate reservoir shall be manufactured of a non corrosive polymide and shall be equipped with a high liquid level indication system to provide system shutdown and to alert the operator that the condensate reservoir is at capacity. The operator shall be alerted that the reservoir is at capacity via a scrolling text display message on the panel mounted operator / compressor interface. Manually operated valves shall be supplied to override the automatic operation of the A.C.D. system for test and maintenance purposes.

Comply _____ Does Not Comply _____

The compressor shall be lubricated by a combination splash and low pressure lubrication system. The final stage of compression shall be lubricated by a pressurized lubrication circuit. The other stages and the driving gear shall be splash lubricated. The low-pressure lubrication circuit shall include a positive displacement oil pump, gear driven by the crankshaft, a non-adjustable oil pressure regulator, and a full-flow oil filter with replaceable element. Two highly visible sight glasses shall be included, one on each of the crankcase to check the oil level. The oil drain hose shall be of sufficient length to reach the outside of the compressor cabinet.

Yes _____ No _____

The final stage and oil pressure gauges shall be mounted on the instrument panel.

Yes _____ No _____

The compressor shall be equipped with an inlet filter with a replaceable particulate element.

Yes _____ No _____

Prime Mover and V-Belt Drive

The three phase electric motor shall be of the open drip-proof (ODP) design and be a true tri-voltage motor. The compressor and motor shall be mounted on a common base that is vibration isolated from the station's main frame. The compressor and motor shall be arranged in a vertical design. Power from the motor shall be transmitted to the compressor by a v-belt drive. The v-belt drive shall be designed to tension the drive belts automatically. Rotation arrows shall be affixed in a conspicuous place on the compressor.

Yes _____ No _____

Electrical Control & Instrumentation

The compressor control panel (CCP) shall include an across-the-line magnetic motor starter, fused transformer and PLC controller. The CCP shall be built in accordance with UL 508A, the standard for Industrial Control Panels and shall be affixed with a UL label.

Yes _____ No _____

The PLC compressor control system consists of a programmable logic controller for the monitoring, protection and control of the compressor systems.

Standard features of the CCP include:

- A NEMA type 4 electrical enclosure
- UL electrical panel
- Human Machine Interface (HMI) with **Multi-Color Touch Screen Display** incorporating vivid TFT (Thin Film Transistor) Technology and NOT limited by touch cells (Optional mounting configurations available-up to 25 ft remote)
- Emergency Stop Palm Button
- Home screen customizable with distributor contact information
- Real Time Clock (time and date)
- Compressor on / off
- Digital Display of Compressor Final Pressure
- Digital Display of Compressor Oil Pressure
- Digital Display of current Compressor Run Time
- Digital Display of Final Separator Cycle Count
- Compressor High Temperature Shutdown and Alarm
- Full support of the Automatic Condensate Drain system (interval and duration set points adjustable thru the HMI - password protected)
 - Digital Display of time to next ACD Cycle
 - Condensate Drain Reservoir full alarm
- Full support of CO monitor alarm functions
- Full support of purification system moisture monitor warning and alarm functions

- Built in overtime timer set at 5 hours - optional times available
- Maintenance Timer (selectable between real time or compressor run time) to give Digital Display of all needed Preventative Maintenance Evolutions
- Motor overload alarm
- Nonresettable hourmeter
- Recoverable Run History (last 5 run periods)
- Recoverable Alarm History (last 5 fault shutdowns)
- Support of up to 5 Languages (to be specified at time of order; includes English, French, Spanish & Portuguese)
- Operator choice of display in BAR or PSI

Yes _____ No _____

For ease of Maintenance and Repair:

- PLC has removable Terminal Blocks for all functions
- Diagnostic EEPROM (Electrically Erasable Programmable Read-Only Memory) Capability
- Support of Two (2) Communication Protocols (optional)
 - o Ethernet Connection
 - o Analog Phone Modem
- Wiring shall be encapsulated within a split corrugated type loom. Each wire end connection shall be machine crimped and numbered.

Yes _____ No _____

The HMI shall have 22 adjustable system parameters secured by password protection. The HMI will provide display of all safety / fault shutdowns with a text read-out of up to three potential causes for the fault / shutdown.

Yes _____ No _____

The compressor oil pressure shall be monitored by a pressure transmitter and digitally displayed on HMI. The compressor shall shut down and a fault will be indicated on the HMI should the compressor's oil pressure drop below the factory preset value during operation. The oil pressure transmitter shall be by-passed during start-up to permit the oil pump to achieve the normal operating pressure.

Yes _____ No _____

The low oil pressure and final air pressure transmitters shall be equipped with sealed electrical connectors. The analog pressure sensors for oil pressure and final pressure shall have adjustable set point and dead-band thru the HMI (password protected).

Yes _____ No _____

A temperature switch shall be supplied on the head of the final stage of compression. The compressor shall shutdown and a fault will be indicated on the HMI should the final stage temperature exceed the tamper-proof set point during operation.

Yes _____ No _____

Fault shut downs shall not affect the ability to fill SCBA cylinders from the storage system as long as there is sufficient pressure in the storage to fill them.

Yes _____ No _____

Purification System

The purification system shall purify high pressure air to a quality that meets or exceeds the requirements of CGA Pamphlet G-7, Compressed Air for Human Respiration, ANSI/CGA G-7.1, Commodity Specification for Air, Grade E, and all other recognized standards for breathing air. Purification shall be achieved by mechanical separation of condensed oil and water droplets, adsorption of vaporous water by a desiccant, adsorption of oil vapor and elimination of noxious odors by activated carbon and conversion of carbon monoxide to respirable levels of carbon dioxide by catalyst. Purification housing and cartridges must be manufactured by the OEM. No systems that use aftermarket housings or cartridges will be accepted. Purification cartridges must be made from aluminum. Systems using plastic purification cartridges will not be accepted.

Yes _____ No _____

The high pressure purification chamber shall have a working pressure of 6000 PSIG. The purification system shall utilize a replaceable cartridge. The purification system shall be designed so that the replacement of the cartridge can be accomplished without disconnecting system piping. The design of the chamber shall preclude the possibility of operating the system without the cartridge installed or with an improperly installed cartridge. A bleed valve shall be provided to vent the purification system to facilitate replacing the cartridge. A pressure maintaining valve and a check valve shall be supplied downstream of the purification system to increase the efficiency of the purification system by maintaining a positive back pressure. A check valve shall be supplied between the coalescing separator on the compressor's discharge line and the purification system to maintain the positive pressure in the purification system when the compressor shuts down.

Yes _____ No _____

The purification system shall include an Electronic Moisture Monitor System. A sensor shall be located in the purifier cartridge for direct monitoring of moisture levels. The system shall warn the operator, in advance, of the impending expiration of the cartridge via a scrolling text display message on the panel mounted operator / compressor interface. The compressor shall shut down automatically and the operator notified via scrolling text display message on the panel mounted operator / compressor interface should the operator fail to change the cartridge within the warning period. The compressor shall not be capable of restarting until the used cartridge is replaced with a new one. The moisture monitoring system shall be of a fail-safe design. Should the electrical contact between the display module and sensor be disconnected, an immediate fault shut down shall be affected. For absolute safety and highest quality breathing air, no manual override shall be supplied for the moisture monitor.

Yes _____ No _____

Fill Control / Instrument Panel

A steel instrument panel affixed with a non-glare Lexan overlay shall be installed on the front of the station. The overlay shall contain an embedded airflow schematic. The instrument panel shall include a storage pressure gauge, an LCD Operator / Compressor Interface, and an emergency stop switch. The instrument panel shall be located and arranged for visibility and easy access by the operator and for accessibility for inspection and maintenance. All components installed in the instrument panel shall be securely supported to eliminate vibration and undue force on instrument piping and to prevent damage during shipment, storage, operation, and maintenance. The fill control / instrument panel shall be hinged for easy maintenance and accessibility.

Yes _____ No _____

The air management control panel shall be factory piped as a Priority Refill System. This system shall simplify the operations panel by eliminating cascade control valves and gauges. The Priority Refill System shall be supplied with a series of pneumatic valves that will direct the air flow directly from the compressor to the SCBA or air storage cylinder. When the storage system pressure drops to the current level of the compressor output, flow from the storage system stops and the compressor alone finishes filling the SCBA bottles. A bypass valve shall be panel mounted allowing the system operator to manually select whether the compressor output shall be directed to the Priority Refill System or directly to the SCBA cylinders, thus giving the operator maximum control of the fill process. Systems without a bypass valve shall not be deemed acceptable as they do not give the operator the flexibility of selecting the air source.

Yes _____ No _____

The control panel shall include, at a minimum, an adjustable regulator for SCBA cylinder fill pressure complete with a pressure gauge for inlet and regulated pressure and a relief valve to protect the SCBA cylinders from overfilling, a manual control valve and pressure gauge for each fill position, the manual bypass direction valve to allow the operator to select SCBA filling from either the Priority Refill System or the compressor, provisions for factory or field modification to allow a different fill pressure at each fill position.

Yes _____ No _____

All control panel mounted pressure gauges shall have a 2 ½” diameter and be liquid filled.

Yes _____ No _____

Air Storage System

The air storage rack shall be in a vertical configuration that is an integral part of the breathing air systems frame. The rack shall be designed and equipped with two (2) 6000 psi rated DOT air storage receivers. Each receiver shall be built to accommodate 509 cubic feet of air at maximum pressure. Additionally, each receiver shall include a service valve and burst disc. The rack shall

be designed to support the receivers in a secure manner and permit visual inspection of the receivers' external surface.

Yes _____ No _____

Containment Fill Station

The front-loading, two position; containment fill station shall totally enclose the SCBA or SCUBA cylinders during the refilling process.

Yes _____ No _____

The fill station's outer enclosure and door assemblies shall be constructed of formed ¼ inch thick plate steel. Venting shall be provided in the bottom of the fill station to allow the rapidly expanding air from a ruptured cylinder to escape from the fill station. The fill station shall be ergonomically designed for maximum operator convenience and safety for refilling cylinders. The fill station door and cylinder holder assembly shall tilt out towards the operator 45 degrees, providing unobstructed access to the cylinder holder to load and unload the cylinders. A heavy-duty gas spring shall be incorporated into the design of the fill station to assist the operator in opening and closing the fill station door. It shall take no more than approximately eighteen pounds of force to open or close the fill station door thereby eliminating operator fatigue.

Yes _____ No _____

Each cylinder holder shall be lined to prevent scuffing the outer surface of the SCBA cylinders. For complete operator protection, the fill station shall include a safety interlock system that will prevent refilling SCBA cylinders unless the fill station door is closed and secured in the locked position. The automatic interlock will require no actuation of secondary latching mechanism on the outside of the fill station.

Yes _____ No _____

Two fill hoses shall be located within the fill station. Each fill hose shall be equipped with a bleed valve and SCBA fill adapter of choice. Fill hose retainers shall be provided to anchor the fill hoses when not in use.

Yes _____ No _____

SCBA fill station must be 3rd party certified to contain the blast from a 5.5 SCBA explosion. Certificate must be included with the bid documents. Units without 3rd party certification will not be accepted.

Yes _____ No _____

Testing and Preparation for Shipment

The breathing air station shall be tested by the manufacturer prior to shipment. A copy of the manufacturer's test report shall be available upon request.

Yes _____ No _____

A manufacturer's nameplate shall be placed on the interior of the electric panel. The nameplate shall include, at a minimum, manufacturer's name, model number, serial number, compressor block number, and date of manufacture. Voltage, phase / frequency, and amperage are located on another label inside the electrical panel

Yes _____ No _____

The station shall be suitably prepared for motor freight transport. The station shall be bolted to a wooden pallet, wrapped in sheet plastic, and fully protected by a wooden crate. The compressor intake and similar openings shall be suitably covered. Component parts, loose parts or associated spare parts shall be packaged separately and shipped on the same pallet if feasible.

Yes _____ No _____

Documentation

A documentation package shall be supplied with the station. The documentation package shall include, at a minimum, an operation manual on USB Drive, recommended spare parts list, warranty information and a start-up/warranty registration form.

Yes _____ No _____

The Operator's Instruction and Maintenance Manual for the breathing air station shall be as detailed as possible, outlining all operation and maintenance instructions. The manual shall include detailed illustrated drawings for the compressor block and all system components along with a complete parts listing for all illustrated components. Warnings and safety precautions shall be identified clearly in the manual.

Yes _____ No _____

Additional Company Information

1. 24 hour Emergency Service/7 Days a week

Yes _____ No _____

2. Provide for emergency service within a 1 hour response time from time of call.

Yes _____ No _____

3. Service center within 50 miles of fire department.

Yes _____ No _____

4. Bidder must allow end user to visit place of manufacture for equipment if desired for inspection/training.

Yes _____ No _____

5. Bidder must be the authorized representative of the product offered for the territory and provide support documentation from factory.

Yes _____ No _____

6. Sufficient factory trained technicians to be able to meet the needs of the customer when service is necessary. Documentation to be provided on factory letterhead with point of contact for verification.

Yes _____ No _____