

LOWCOUNTRY AREAWIDE WATER QUALITY MANAGEMENT PLAN

Amendment 22

The Point South Wastewater Treatment Plant (WWTP) may be expanded from a capacity of 125,000 GPD to a permitted capacity of 490,000 GPD. The expansion will include the following improvements:

- **Phase I.** Additional spray fields will be increased from 17.7 acres to 31 acres to increase capacity from current 125,000 GPD to 200,000 GPD.
- **Phase II.** An upgrade of the entire facility, effluent holding, effluent pump station and effluent spray field to provide treatment and effluent disposal for 490,000 GPD to meet current and future needs.