

LOWCOUNTRY AREAWIDE WATER QUALITY MANAGEMENT PLAN

Amendment 23

The Hardeeville Wastewater Treatment Plant (WWTP) may be expanded to maximize flows under current TMDL allocations from a capacity of 1.01 MGD to a Phase 1 capacity of 2.7 MGD. The proposed improvements to accommodate the expansion will generally consist of influent screening and grit removal, traditional extended aeration activated sludge treatment, secondary clarification, tertiary filtration and disinfection.