



METER INSTALLATION DIMENSIONS

METER SIZE	A	B	C	D
5/8"	12 1/2"	9 5/16"	9"	4"
3/4"	15"	9 1/4"	9 3/4"	5 3/8"

NOTES:

1. NOT FOR INSTALLATION IN ROADWAYS OR PARKING AREAS, DRIVEWAYS OR SIDEWALKS.
2. IF SURFACE IS NOT TO FINAL GRADE AT TIME OF INSTALLATION OF METER, OR GRADE CHANGES AFTER INSTALLATION, OWNER MUST ADJUST PIT TO MEET SPECIFICATIONS.
3. METER SETTING MUST BE INSPECTED BEFORE BACKFILLING. FOR INSPECTION CALL (970) 587-4331 LOCATION OF METER SHALL BE 2 FEET DOWNSTREAM OF THE CURB STOP UNLESS OTHERWISE PLACED BY METER SERVICES.
4. NO CONCRETE FLOOR TO BE POURED IN METER PIT.
5. NO SPRINKLER SYSTEM CONNECTIONS SHALL BE MADE IN THE METER PIT. SPRINKLER PIT SHALL BE MINIMUM 5 FT DOWNSTREAM FROM METER PIT, MEASURED EDGE TO EDGE.
6. NO MAJOR LANDSCAPING OR STRUCTURES SHALL BE LOCATED WITHIN 10 FT OF THE METER PIT.
7. IF PRESSURE REDUCING VALVE IS REQUIRED BY PLUMBING CODE, IT SHALL BE INSTALLED INSIDE THE BUILDING, IMMEDIATELY FOLLOWING THE MAIN WATER SHUT OFF VALVE.
8. COPPER SHALL SHOW NO VISIBLE CRIMPING.
9. REFER TO TOWN OF MILLIKEN WATER & SEWER CONSTRUCTION SPECIFICATIONS, CURRENT VERSION, FOR PRODUCT SPECIFICATIONS.



OUTSIDE SETTING FOR 5/8" & 3/4" METER

DETAIL NO. W-7

DATE: APRIL, 2020

SCALE: N.T.S.