

# Pasco County Utilities Emergency Rule Notification

---

- Installation Name: **Pasco County Master Reuse System**
- Installation Address: **7536 Little Road, Suite 213, New Port Richey, FL 33654**
- For further information, contact Micah Minaberry, Utilities Planner II:  
813-929-2755 ext. 6967 or 727-207-2773 (Cell)
- Permit Number (if applicable): **FLA127272**
- Date and time of the incident or discovery: **DATE: 13 May 2024 TIME: 11:32 AM**
- Location of the incident or discovery: **Little Road/Plathe Road New Port Richey, FL 33653**
- Suspected source and cause of incident or discovery: **Reclaimed Pipe failure**
- Type of pollution, including substance or contaminant name(s): **Treated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Discovery of a 6 to 7 foot split in the reclaimed water line caused the release of approximately 12,500 gallons of treated domestic wastewater into the Pithlachascotee River (0 gallons retrieved). Spill was isolated and ceased.**
- Source: (e.g. land, water, air) affected: **LAND:  X  WATER:  X  AIR:**
- Potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High   Medium   Low   None  X**
- Identification of other parties notified of incident and time notification occurred:

Name: **(FDEP) Emmalise Hunter** Time Notified: **(24 Hour) X (48 Hour)**

Name: **(Michael Carballa)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Branford Adumuah)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Ron Oakley –BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**

- Additional information that may be helpful: **MAP #092, WO#1364924, SSO #1326. Waterways were affected, however, there is no risk to public health.**