

Pasco County Utilities Emergency Rule Notification

- Installation Name: **Embassy Hills Wastewater Treatment Facility**
- Installation Address: **9512 Crabtree Lane, Port Richey, FL 34668**
- For further information, contact Micah Minaberry, Utilities Planner II:
813-929-2755 ext. 6967 or 727-207-2773 (Cell)
- Permit Number (if applicable): **FLA012735**
- Date and time of the incident or discovery: **DATE: 22 April 2024 TIME: 12:20 PM**
- Location of the incident or discovery: **Self Storage on Sterling Lane, Port Richey, FL 34668**
- Suspected source and cause of incident or discovery: **Contractor struck 10" forcemain**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 5250 gallons of untreated domestic waste (5250 gallons recovered). Soil was excavated and clean fill was brought in.**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: AIR:**
- Potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High Medium Low None X**
- Identification of other parties notified of incident and time notification occurred:

Name: **(FDEP) Emmalise Hunter** Time Notified: **(24 Hour) X (48 Hour)**

Name: **(Michael Carballa)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Branford Adumuah)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Ron Oakley –BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**

- Additional information that may be helpful: **MAP #53, SSO #1321. No waterways were affected and there is no risk to public health.**