

# Pasco County Utilities Emergency Rule Notification

---

- Installation Name: **Land O Lakes Wastewater Treatment Facility**
- Installation Address: **6003 Parkway Boulevard Land O Lakes, FL 34639**
- For further information, contact Micah Minaberry, Utilities Planner II:  
813-929-2755 ext. 6967 or 727-207-2773 (Cell)
- Permit Number (if applicable): **FLA012731**
- Date and time of the incident or discovery: **DATE: 22 July 2024 TIME: 11:18 PM**
- Location of the incident or discovery: **2220 Collier Parkway Land O Lakes, FL 34639**
- Suspected source and cause of incident or discovery: **Force main break**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Dispatch was called at 11:18am from a citizen who was concerned about water seeping from a crack in the Academy at the Lakes parking lot. Maintenance arrived at 11:30am, determined that it was a broken force main pipe, and isolated and ceased the spill by closing a valve. The broken pipe caused the release of approximately 100 gallons of untreated domestic wastewater. A vactor was used to retrieve all the liquids. Lime was spread at the site was washed in with approximately 200 gallons of potable water. The force main was repaired and the system reactivated. There was no impact to any body of water, and no harm to human health.**
- Source: (e.g. land, water, air) affected: **LAND:  X  WATER:   AIR:**
- Potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High   Medium   Low   None  X**
- Identification of other parties notified of incident and time notification occurred:

Name: **(FDEP) Emmalise Hunter** Time Notified: **(24 Hour) X (48 Hour)**

Name: **(Michael Carballa)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Branford Adumuah)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Ron Oakley –BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**

- Additional information that may be helpful: **MAP # 348, SSO # 1336. No waterways were affected and there is no risk to public health.**