

Pasco County Utilities Emergency Rule Notification

- Installation Name: **New Port Richey Wastewater Treatment Facility**
- Installation Address: **4730 Main Street New Port Richey, FL 34652**
- For further information, contact Micah Minaberry, Utilities Planner II:
813-929-2755 ext. 6967 or 727-207-2773 (Cell)
- Permit Number (if applicable): **FL0127434**
- Date and time of the incident or discovery: **DATE: 29 May 2024 TIME: 12:10 PM**
- Location of the incident or discovery: **13th Avenue, New Port Richey, FL 34653**
- Suspected source and cause of incident or discovery: **ARV failure**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Piping came loose from a valve, causing the release of approximately 100 gallons of untreated domestic wastewater. Spill was ceased and isolated. Valve was removed and replaced with straight pipe. 100 gallons of wastewater was retrieved. Site was washed down with approximately 200 gallons of fresh water and 15 lbs. of lime was spread. No waterways were affected and there is no risk to public health.**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: AIR:**
- Potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High Medium Low None X**
- Identification of other parties notified of incident and time notification occurred:

Name: **(FDEP) Emmalise Hunter** Time Notified: **(24 Hour) X (48 Hour)**

Name: **(Michael Carballa)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Branford Adumuah)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Ron Oakley –BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**

- Additional information that may be helpful: **MAP #40, SSO #1330. No waterways were affected and there is no risk to public health.**