

# Pasco County Utilities Emergency Rule Notification

---

- Installation Name: **Shady Hills Wastewater Treatment Facility**
- Installation Address: **14220 Hays Road, Spring Hill, FL 33610**
- For further information, contact Meghan Harbaugh, Environmental Compliance Specialist: 813-929-2755 ext. 6904 or 727-992-5983 (Cell)
- Permit Number (if applicable): **FLA012741**
- Date and time of the incident or discovery: **DATE: 23 July 2024 TIME: 4:39 PM**
- Location of the incident or discovery: **2208 Duck Slough Dr Trinity, FL 34655**
- Suspected source and cause of incident or discovery: **Maintenance received a call from dispatch at 4:39 pm that an ARV was leaking on Duck Slough Ave. Crew arrive onsite at 5 pm and determined there was a failure of the ARV. The spill was ceased by attaching a corporation fitting and a compression coupling. The ARV failure caused the release of approximately 150 gallons of untreated domestic wastewater into a storm drain. A Vactor retrieved approximately 1500 gallons of liquid from the storm basin. 150 lbs of lime was spread, and the site was washed down with over 100 gallons of potable water. There was no impacts to any waterways, and no public health concerns.**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 150 gallons of untreated domestic waste (1500 gallons liquid retrieved from storm basin). Used lime and clean water to neutralize and restore site.**
- Source: (e.g. land, water, air) affected: **LAND:  X  WATER:   AIR:**
- Potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High   Medium   Low   None  X**
- Identification of other parties notified of incident and time notification occurred:

Name: **(FDEP) Emmalise Hunter** Time Notified: **(24 Hour) X (48 Hour)**

Name: **(Michael Carballa)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Branford Adumuah)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Ron Oakley –BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**

- Additional information that may be helpful: **MAP #131, W/O #1423042, SSO #1337. Spill ceased and site cleaned. Lime was spread. No waterways were impacted and there is no risk to public health.**