

# Pasco County Utilities Emergency Rule Notification

---

- Installation Name: **Shady Hills Wastewater Treatment Facility**
- Installation Address: **14220 Hays Road, Spring Hill, FL 33610**
- For further information, contact Meghan Harbaugh, Environmental Compliance Specialist: 813-929-2755 ext. 6904 or 727-992-5983 (Cell)
- Permit Number (if applicable): **FLA012741**
- Date and time of the incident or discovery: **DATE: 10 July 2024 TIME: 1:28PM**
- Location of the incident or discovery: **Agua Clara Drive Hudson, FL 34667**
- Suspected source and cause of incident or discovery: **A call was received at 1:28 PM from the HOA of the Bayonet Point community of a possible leak in the bypass pumps located onsite. Upon arrival at 1:45 PM, Barry Harris noted that there was a split in one of the hoses, and shut the pump off, ceasing the spill at 1:50 PM. There was no standing water, but it is estimated that approximately 20 gallons of untreated domestic wastewater had soaked into the ground. No water was retrieved, but the site was jetted with fresh water and 1 bag of lime was spread. The company that manages the pumps for the bypass system was called onsite and the damaged hose was replaced.**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 20 gallons of untreated domestic waste (0 gallons untreated domestic waste recovered). Used lime and clean water to neutralize and restore site.**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: \_\_\_\_\_ AIR: \_\_\_\_\_**
- Potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High \_\_\_ Medium \_\_\_ Low \_\_\_ None X**
- Identification of other parties notified of incident and time notification occurred :

Name: **(FDEP) Emmalise Hunter** Time Notified: **(24 Hour) X (48 Hour)**

Name: **(Michael Carballa)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Branford Adumuah)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Ronald E. Oakley –BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**

- Additional information that may be helpful: **MAP # 65, W/O # 916711, SSO #1335. Spill ceased and site was cleaned with fresh water. Lime was spread. No waterways were impacted and there is no risk to public health.**