

Pasco County Utilities Emergency Rule Notification

- Installation Name: **Shady Hills Wastewater Treatment Facility**
- Installation Address: **14220 Hays Road Spring Hill, FL 34610**
- For further information, contact Micah Minaberry, Utilities Planner II:
813-929-2755 ext. 6967 or 727-207-2773 (Cell)
- Permit Number (if applicable): **FLA012741**
- Date and time of the incident or discovery: **DATE: 20 May 2024 TIME: 9:40 AM**
- Location of the incident or discovery: **11544 Ranchers Gap Rd, Odessa, FL 33556**
- Suspected source and cause of incident or discovery: **ARV failure**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Dispatch received a call at 9:40am. A broken ARV was leaking untreated wastewater (approximately 10 gallons) onto the sidewalk and grassy area. First responders arrived on site and the spill was ceased by turning the ball valve off. ARV was replaced, Site was cleaned with approximately 200 gallons of fresh water. 1 bag of lime was spread around the spill location. No water was retrieved. No waterways were affected and there is no danger to public health.**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: AIR:**
- Potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High Medium Low None X**
- Identification of other parties notified of incident and time notification occurred:

Name: **(FDEP) Emmalise Hunter** Time Notified: **(24 Hour) X (48 Hour)**

Name: **(Michael Carballa)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Branford Adumuah)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Ron Oakley –BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**

- Additional information that may be helpful: **MAP #148, SSO #1329. No waterways were affected and there is no risk to public health.**