

# Pasco County Utilities Emergency Rule Notification

---

- Installation Name: **Wesley Center Wastewater Treatment Facility**
- Installation Address: **7501 Boyette Blvd Wesley Chapel, FL 33544**
- For further information, contact Micah Minaberry, Utilities Planner II:  
813-929-2755 ext. 6967 or 727-207-2773 (Cell)
- Permit Number (if applicable): **FLA016094**
- Date and time of the incident or discovery: **DATE: 08 May 2024 TIME: 2:19 PM**
- Location of the incident or discovery: **32372 Conchshell Sail Drive, Zephyrhills, FL 33545**
- Suspected source and cause of incident or discovery: **Mega flange failure**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Failure of a mega flange caused the release of approximately 211 gallons of untreated domestic wastewater into a storm drain. Storm drain was cleared with a vac truck (150 gallons retrieved), area was washed with fresh water and 50 lbs. of lime was spread around the area. No water ways were affected.**
- Source: (e.g. land, water, air) affected: **LAND:  X  WATER:   AIR:**
- Potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High   Medium   Low   None  X**
- Identification of other parties notified of incident and time notification occurred:

Name: **(FDEP) Emmalise Hunter** Time Notified: **(24 Hour) X (48 Hour)**

Name: **(Michael Carballa)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Branford Adumuah)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Ron Oakley –BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**

- Additional information that may be helpful: **MAP #521, SSO #1325. No waterways were affected and there is no risk to public health.**