

Pasco County Utilities Emergency Rule Notification

- Installation Name: **Wesley Center Wastewater Treatment Facility**
- Installation Address: **7501 Boyette Blvd Wesley Chapel, FL 33544**
- For further information, contact Micah Minaberry, Utilities Planner II:
813-929-2755 ext. 6967 or 727-207-2773 (Cell)
- Permit Number (if applicable): **FLA016094**
- Date and time of the incident or discovery: **DATE: 28 July 2024 TIME: 8:18 AM**
- Location of the incident or discovery: **9958 Mckendree Rd San Antonio, FL 33576**
- Suspected source and cause of incident or discovery: **Broken Force Main Pipe**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **8:18am maintenance received a call from dispatch of a pipe break that smelled like sewage. 8:32am personnel arrived onsite and determined that there was a break in a 12" force main pipe. Due to the large pipe size, spill was not isolated until 12:52pm, due to needing enough trucks to maintain the system functionality. Valves were closed and spill was ceased. An excavator dug up the site and it was discovered that the 12" force main was broken. This caused the release of approximately 98,629 gallons of untreated domestic wastewater. Approximately 10,400 gallons were recovered from the excavated area, while the remainder went into the cow pasture and dried up. This dirt was removed from the site via trucks and clean dirt was backfilled around the spill site. 26 bags of lime were spread around the site. Broken section of pipe was cut-out, and replaced with a sleeve and 72" of new pipe. Excavated area of pipe repair was backfilled. There were no impacts to any water bodies and no harm to human health.**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: AIR:**
- Potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High Medium Low None X**
- Identification of other parties notified of incident and time notification occurred:

Name: **(FDEP) Emmalise Hunter** Time Notified: **(24 Hour) X (48 Hour)**

Name: **(Michael Carballa)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Branford Adumuah)** Time Notified: **(24 Hour) (48 Hour)**

Name: **(Ron Oakley –BOCC Chairman)** Time Notified: **(24 Hour) (48 Hour)**

- Additional information that may be helpful: **MAP #465, SSO #1340, EAM WO#1424831. No waterways were affected and there is no risk to public health.**