

## Appendix A to OWTS Regulation

**Local Public Health Agency:** Prowers County

CROSSWALK				
ITEM	REQUIREMENTS See Check Box for Decision Chosen.		Citation Reg #43	Citation Local Reg
Occupancy – Residential	Bedrooms 1 through 3: 2 people per bedroom All additional Bedrooms: 1 person per bedroom	<input checked="" type="checkbox"/>	43.6.A.2e	
	All bedrooms: 2 persons per bedroom	<input type="checkbox"/>	43.6.A.2.f	
How the number of bedrooms in a home will be defined for flow requirements	Bedrooms: flow estimates will be determined from the number of bedrooms originally finished.	<input checked="" type="checkbox"/>		
	If unfinished area is present in house, system must also be sized for 1 or 2 more bedrooms based on an assumption that 150 square feet of unfinished space can be converted into a bedroom, if the space can meet applicable code requirements for a bedroom.	<input type="checkbox"/>	43.6.A.2.h	
Effluent Screen	May be used ( <i>owner's option</i> )	<input checked="" type="checkbox"/>	43.9.J.1	
	Required in all new septic tanks	<input type="checkbox"/>	43.9.J.1	
Length of Distribution Laterals (e.g., trenches or beds)	Limit the length of distribution lines to a maximum of 100 feet.	<input type="checkbox"/>	43.10.E.2.c	
	100 feet maximum for gravity fed from one end, and up to 150 feet if pressure dosed or effluent applied at center of lateral or chamber	<input checked="" type="checkbox"/>	43.10.E.2.b & c	
Inspection ports at initial (front) end of distribution line (e.g., lateral or chamber)	Not required	<input checked="" type="checkbox"/>		
	Required	<input type="checkbox"/>	43.10.F.6.d	
Vault Privies – new	Allow new vault privies	<input checked="" type="checkbox"/>	43.12.D.1.a	
	Prohibit new vault privies	<input type="checkbox"/>	43.12.D.1.a	
Vault Privies - existing	Allow continued use of existing vault privies	<input checked="" type="checkbox"/>	43.12.D.1.b	
	Require abandonment of existing vault privies	<input type="checkbox"/>	43.12.D.1.b	
Pit Privies - new	Allow new pit privies	<input checked="" type="checkbox"/>	43.12.D.2.c	
	Prohibit new pit privies	<input type="checkbox"/>	43.12.D.2.a	
Pit Privies - existing	Allow continued use of existing pit privies	<input checked="" type="checkbox"/>	43.12.D.2.c	
	Require abandonment of existing pit privies	<input type="checkbox"/>	43.12.D.2.b	
Slit trenches	Allow slit trenches	<input checked="" type="checkbox"/>	43.12.F	
	Prohibit slit trenches	<input type="checkbox"/>	43.12.F	
Reductions in STA size or separation distances for higher level treatment systems; OWTS O/M and LPHA oversight required	Allow reductions for higher level treatment.	<input type="checkbox"/>	43.14.D.2	
	Reductions for higher level treatment not allowed	<input checked="" type="checkbox"/>	43.14.D.3	
Transfer of Title inspections	Inspection of OWTS required prior to transfer of title	<input type="checkbox"/>	43.4.L.1	
	Inspection of OWTS NOT required	<input checked="" type="checkbox"/>	43.4.L.1	