



NOTES:

1. CONCRETE SHALL MEET THE REQUIREMENTS OF SECTION 337.10 OF THE LATEST EDITION OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION.
2. ALL CONCRETE SIDEWALK SHALL HAVE $\frac{1}{2}$ " EXPANSION JOINTS EVERY 30 FEET AND AT ALL CURB RETURNS. WEAKENED PLANE JOINTS SHALL BE EVERY 5 FEET AND COINCIDE WITH THE ADJACENT CURB AND GUTTER WEAKENED PLANE JOINTS. THE WEAKENED PLANE JOINTS PLACED EVERY 5' IN THE SIDEWALK MAY BE SAWCUT WITH CITY OF ELKO APPROVAL AND SHALL MEET THE REQUIREMENTS OF SECTION 314 OF THE LATEST EDITION OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION.
3. AGGREGATE BASE MATERIAL SHALL MEET THE REQUIREMENTS OF SECTION 302 & 308 OF THE LATEST EDITION OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION.
4. FORESLOPES & BACKSLOPES SHALL BE APPROVED BY THE CITY OF ELKO PRIOR TO CONSTRUCTING.
5. CROSS SLOPE OF SIDEWALK SHALL NOT EXCEED 2%.

NO.	REVISION	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION	
			SIDEWALK	ROADWAY	
CITY OF ELKO, NEVADA		DRAWING NO.			
		R-3.1			
			DATE	PAGE	
			11/30/07	1	