



**NOTES:**

- AIR RELEASE VALVES SHALL BE INSTALLED OUTSIDE PAVEMENT SECTION. SLOPE GROUND AWAY FROM VALVE BOX OR CONSTRUCT CURBING TO PROTECT FROM FLOODING BY SURFACE WATERS.
- ALL PIPES SHALL HAVE POSITIVE SLOPE FROM MAIN LINE TO AIR RELEASE VALVE.

NO.	REVISION	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION
1	3/4" IPS	7/15/19	POTABLE WATER	UTILITIES
			AIR RELEASE	DRAWING NO.
			CITY OF ELKO, NEVADA	U-10.1
				DATE
				7/15/2019
				PAGE
				1