



**NOTES:**

1. 4' WATER METER BOX SHALL BE MUELLER / McCULLOUGH THERMA-COIL METER BOX.
2. NO MORE THAN ONE EXTENSION ALLOWED.
3. LOCATE WATER METER 1 FT. BEHIND THE PROPERTY LINE AND LOCATED IN THE UTILITY EASEMENT.

|     |            |      |   |                       |      |
|-----|------------|------|---|-----------------------|------|
| NO. | REVISION   | DATE | STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION<br>3/4" & 1" WATER METER | SECTION<br>UTILITIES  |      |
| 1   | 1-HOLE LID | 1/13 |   | DRAWING NO.<br>U-13.1 |      |
|     |            |      | CITY OF ELKO, NEVADA  | DATE                  | PAGE |
|     |            |      |   | 11/30/07              | 1    |