



**NOTES:**

1. DOUBLE CHECK VALVE BACKFLOW ASSEMBLY SHALL BE APPROVED BY THE CITY OF ELKO UTILITIES & TESTED BY AN APPROVED CERTIFIED BACKFLOW ASSEMBLY TESTER PRIOR TO APPROVAL OF ANY CERTIFICATE OF OCCUPANCY.
2. NO OUTLET TEE, TAP OR CONNECTION BETWEEN SERVICE CONNECTION & BACKFLOW PREVENTION ASSEMBLY.
3. SUPPORTS REQUIRED FOR ASSEMBLIES 2.5" AND LARGER.
4. ELECTRICAL CONDUIT TO BE MOUNTED AND FASTENED ON THE SIDE WALLS OF THE VAULT & SHALL NOT BE MOUNTED SO AS TO OBSTRUCT ACCESS TO MAINTAIN AND TEST ASSEMBLY.
5. WATER TIGHT IN HIGH GROUND WATER AREAS, PLUG DRAIN HOLES.
6. LOCATE DIRECTLY BEHIND WATER METER, ALL OTHER LOCATIONS REQUIRE PRIOR APPROVAL BY CITY OF ELKO UTILITIES DEPARTMENT.
7. BACKFLOW PREVENTER ASSEMBLIES SHALL MEET THE REQUIREMENTS OF NAC 445A.67185-67255.

NO.	REVISION	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION	
			BACKFLOW PREVENTER ASSEMBLY (DOUBLE CHECK TYPE)	UTILITIES	
				CITY OF ELKO, NEVADA	DRAWING NO.
			U-16.1		DATE
				11/30/07	1