



NOTES:

1. AIR RELEASE VALVES SHALL BE INSTALLED OUTSIDE PAVEMENT SECTION. SLOPE GROUND AWAY FROM VALVE BOX OR CURBING TO PROTECT FROM FLOODING OF SURFACE WATERS.
2. ALL PIPES SHALL HAVE POSITIVE SLOPE FROM MAIN LINE TO AIR/VACUUM VALVE.
3. SPECIAL CONDITIONS REQUIRE SPECIAL SIZING.

NO.	REVISION	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION UTILITIES
			RECLAIMED WATER	DRAWING NO. U-18.1
			AIR / VACUUM	DATE 11/30/07
			CITY OF ELKO, NEVADA	PAGE 1