



NOTES:

1. HYDRANTS SHALL BE ENAMELED RED.
2. ALL HYDRANTS SHALL HAVE (2) 2.5" PUMPER OUTLETS (MALE THREAD WITH CAP & CHAIN) AND (1) 4.5" STEAMER PUMPER OUTLET WITH 4.5" - 5" STORZ FEMALE CONNECT WITH CAP & CHAIN. ALL THREADS SHALL BE SPECIFIED FOR AMERICAN NATIONAL HOSE COUPLING.
3. OPERATING NUT SHALL BE 1.5" PENTAGON.
4. INSPECTION BY A CITY OF ELKO FIRE OR PUBLIC WORKS REPRESENTATIVE IS REQUIRED PRIOR TO BACKFILLING.
5. FOR FINAL ACCEPTANCE, A FLOW, FLUSH, & HYDROSTATIC TEST SHALL BE WITNESSED BY CITY OF ELKO FIRE DEPT./UTILITY DIRECTOR OR PUBLIC WORKS REPRESENTATIVE, PER FORM 13-97, "MATERIALS & TEST CERTIFICATE FOR UNDERGROUND PIPING".
6. ALL HYDRANT SHALL INCLUDE APPROVED TRAFFIC PROTECTION, 3' MINIMUM CLEARANCES, AND POSITIVE DRAINAGE AWAY FROM THE HYDRANT.

NO.	REVISION	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION UTILITIES
1	C-900	11/14	FIRE HYDRANT	DRAWING NO. U-1.2
			CITY OF ELKO, NEVADA	DATE 11/30/07 PAGE 1