



NOTES:

1. IN NO CASE SHALL A LATERAL CONNECT TO THE SEWER MAIN DIRECTLY ON TOP OR MATCH THE FLOWLINE OF THE PIPE.
2. SEWER LATERALS SHALL HAVE A MINIMUM SLOPE OF 2%.
3. ALL JOINTS ON SEWER LATERAL PIPE WITHIN THE RIGHT-OF-WAY SHALL BE COMPRESSION TYPE.
4. LATERAL SHALL EXTEND TO PROPERTY LINE UNLESS OTHERWISE SHOWN ON PLANS.
5. SADDLE CONNECTION SHALL BE PVC SADDLE WITH STAINLESS STEEL STRAPS.
6. ANY ABANDONED SEWER LATERAL IS THE RESPONSIBILITY OF THE CUSTOMER AND SHALL BE CUT AND CAPPED OR PLUGGED WITHIN 6 INCHES OF THE SEWER MAIN AND SUBJECT TO THE CITY OF ELKO'S APPROVAL.
7. SEWER MAIN/LATERAL CONNECTIONS SHALL MEET THE REQUIREMENTS OF NAC 445A.

NO.	REVISION	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION UTILITIES	
			SEWER LATERAL CONNECTION	DRAWING NO. U-6.1	
			CITY OF ELKO, NEVADA	DATE 11/30/07	PAGE 1