



Note: If 1 can not be constructed, then locate sewer service lateral in such a manner as is authorized by the Nevada Division of Environmental Protection.

1

Note: Construct 2a, If can not construct 1. If water main or water service lateral is in place at the time a sewer main is constructed and must be relocated to meet vertical clearance, the relocation shall be performed with the approval of and in accordance with the procedures & standards of the supplier of water.

2A

Note: Construct 2b, If can not construct 1. If water main or water service lateral is in place at the time a sewer main is constructed and must be relocated to meet vertical clearance, the relocation shall be performed in such a manner as is authorized by the Nevada Division of Environmental Protection.

2B

SEWER LATERAL CROSSING WATER MAIN OR WATER SERVICE LATERAL

NOTES:

1. SEWER SERVICE LATERAL CROSSING WATER MAIN OR WATER SERVICE LATERAL SHALL MEET THE REQUIREMENTS OF NAC 445A.67175.

NO.	REVISION	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION UTILITIES
			CROSSING LINE SEPARATION	DRAWING NO.
			SEWER LATERAL CROSSING WATER MAIN/LATERAL	U-8.1
			CITY OF ELKO, NEVADA	DATE
				11/30/07
				PAGE
				1